



cfo@suratmunicipal.org



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2021/00006532

Date: 13/07/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2021/00006532/R1

Building Occupancy/Category: Educational (non-residential)

To,

Vivek Kumar Singh  
BLOCK NO. 147 CANAL ROAD VILLAGE LADVI SURAT Surat MC 394325  
Fire Region: Surat MC  
Mobile No: 7600744946 Email ID: vs7600744946@gmail.com

This has reference to your Application No. 2024/00070747 dated 03/07/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise MAHESHWARI PUBLIC SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: SURAT
5. Name of Block(s): MAHESHWARI PUBLIC SCHOOL

The building/premise was inspected on 13/07/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 13/07/2024
2. Six monthly inspection was done on 13/07/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 13/07/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



### Digitally Verified

Digitally verified by: Hardik Pramodkumar Kansara  
Fire Safety Officer - General (FSO-G)  
2021/000016

Date: 13/07/2024  
Time: 09:07 AM



Principal

Shantadevi Sitaram Mundra

Mareshwari Public School

Block No. 147, Canal Road

LADVI, SURAT

Manager

Shantadevi Sitaram Mundra

Mareshwari Public School,

Block No. 56, Canal Road,

LADVI, SURAT

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.