



cfo@suratmunicipal.org



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2021/00006532

Date: 31/07/2026

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2021/00006532/R2

Building Occupancy/Category: Educational (non-residential)

To,

Shanta Devi Sitaram mundra Maheshwari public school
BLOCK NO. 147 CANAL ROAD VILLAGE LADVI SURAT Surat MC 394325
Fire Region: Surat MC
Mobile No: 9099947636 Email ID: Mps.Ladvi@yahoo.com

We have received Application No.2026/00207821 dated 21/07/2026 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise Shantadevi Sitaram mundraMAHESHWARI PUBLIC SCHOOL(nar Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:56
4. Village Name: Ladvi
5. Name of Block(s): 147

The building/premise was inspected on 31/07/2026 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM

1. Emergency drill was carried out on 28/07/2026 12:02:46 PM
2. Six monthly inspection was done on 28/07/2026 3:08:57 PM

The Fire Safety Certificate is renewed for a period of two (2) years upto 31/07/2028 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:29/07/2026 3:54:11 PM



Digitally Verified

Digitally verified by: Hardik Pramodkumar Kansara
Fire Safety Officer - General (FSO-G)
2021/000016
Reviewed by : CFO Surat MC
Date: 31/07/2026
Time: 08:21 AM



Principal

Shantadevi Sitaram Mundra Maheshwari Public School,
Block No. 147 Canal Road
LADVI, SURAT

FSCA/O/CFOSMC/2021/00006532/R2

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in

Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill

Shantadevi Sitaram Mundra Maheshwari Public School,
Block No. 56, Canal Road,
LADVI, SURAT.